



1st - Vista Ridge Point Addn_Markup Summary

Lauren Cook (9)



Author: Lauren Cook

should be at 1 in = 1000 ft scale



Author: Lauren Cook


Include space that lists each submittal date



Author: Lauren Cook


Page should be 34 x 22in

Page should be 34 x 22in




Author: Lauren Cook

misspelled




Author: Lauren Cook

boundary distinction between zone AE and X unclear




Author: Lauren Cook

not sure what this 5' setback is for, build-to line for land in 1-35E is 10'



Author: Lauren Cook




Author: Lauren Cook


This approval block is incorrect. Please use the correct version to the right of this text box.

Author: Lauren Cook

Karen Locke




nrezaei (2)



Author: nrezaei

Add the additional sanitary easement. Inst.# 2013-33596, O.R.D.C.T.



Author: nrezaei

Floodplain area nd drainage easement lines should match